



Addendum No. 1

To the RFP for the Air Compressor Equipment and Installation

For the Spiro Water Treatment Plant

1884 Three Kings Drive Park City, Utah 84060

November 26, 2014

1. Park City Municipal Corporation has extended the due date for this RFP. The new due date for the proposals is **December 15, 2014** by 4:00 pm Mountain Standard Time. The selection of a provider is scheduled to be made by close of business December 19, 2014 and a subsequent contract to be taken to City Council for their approval on January 8, 2015.
2. Clarification: A question has been received regarding the building permit requirement, and if the work needs to be performed by a certified licensed contractor, plumber and electrician. The following Park City Municipal Corporation Building Department requirements shall be relied upon for bidding purposes:
 - The setting of the air compressor equipment does not require a certified licensed contractor. The installation of the airline piping connections to the compressor equipment and existing airline piping will require a licensed contractor and does not require a City Building Permit.
 - The licensed Electrical contractor will be provided by the City and will be responsible for the building permit associated with the electrical work. Bidder shall provide drawings and electrical requirements.
3. Clarification: A housekeeping pad will be provided by the City for the air compressor equipment to set on. Bidder shall provide requirements/ dimensions needed for the air compressor system
4. Clarification: Copper piping will be used to connect new air system to existing inch and a quarter black metal air piping