

City Park Survey RFP  
Questions  
4-17-17

- Q. Phase 1 – Survey
- a. **Existing utility locations** (Does this mean we research utility records and connect the survey dots or Do we need to hire a SUE provider and trace and survey existing utilities?)
  - b. Same question for **Drainage Facilities** ( Will a survey shot be sufficient or do need to document the and measure the condition of each drainage feature?)
- A. Existing utilities that are visible should be mapped, i.e. storm drain grates, manhole covers, water valves, poles, pedestals, transformers... We do not need underground lines traced or bluestaked.
- Q. For the Phase 1 Survey work, the RFP states that **existing vegetation** (size and botanical name noted) must be identified on the survey map. Does "existing vegetation" include trees only (say above a certain size) or is the City requesting that all vegetation (i.e., trees, shrubs, groundcover) be inventoried and shown on the survey?
- A. It means trees but the dense clump areas can be clouded and noted "containing species of ...". If there are significant trees over 6" Diameter (DBH) they should be noted.
- Q. Last sentence for Phase 1 – Survey. **The selected contractor shall also be required to obtain a Park City Municipal business license.** What does this mean if our office is in Sandy, Utah?
- A. Park City requires all contracted consultants obtain a Park City Business License. It is a General Business License for work out of a vehicle. More information can be found at:  
<http://www.parkcity.org/departments/finance-accounting/business-licenses/general-business-license>